

SUB DIVISION WATER TESTING LABORATORY BEOHARI

PUBLIC HEALTH ENGINEERING DEPARTMENT SUB DIVISION BEOHARI District- Shahdol (M.P.)

Test Report

Nature of Sample: Tubewell Water			
Particular Of Sender: Central Acadmey International School Mau			
Particular Of Sample: Not Collected by PHED			
Sample Collection Date	16.02.2026	Sample receiving date	16.02.2026
Date of Analysis	16.02.2026	Date of End Analysis	17.02.2026

Sample Details:

Sample no.	Block	Gram panchayat	Village	Particulars of samples	Quantity of samples	Condition of sample
182	Beohari	Mau	Mau	Central Acadmey International School	1Liter	OK

Physical , Chemical and Bacteriological Test Report with Details of Parameters

S. No	Characteristics	Unit	As per the BIS 10500:2012		Sample No.
			Desirable limit	Permissible limit	
					182
1	pH at 25°C	pH	6.5 - 8.5	NO RELAXATION	7.2
2	Odor	-	Agreeable	Agreeable	Agreeable
3	Color	Hazen	5	15	6
4	Taste	-	Agreeable	Agreeable	Agreeable
5	Total Alkalinity as CaCo3	Mg/l	200	600	350
6	Total Hardness as CaCo3	Mg/l	200	600	400
7	Calcium as Ca++	Mg/l	75	200	-
8	Magnesium as Mg++	Mg/l	30	100	-
9	Chlorides as Cl ⁻	Mg/l	250	1000	40
10	Turbidity	NTU	1	5	2.8
11	Electrical Conductivity at 25°C	µmho/cm	-	-	-
12	Nitrates (As NO ₃)	mg/l	45	45	-
13	Total Dissolved Solids	mg/l	500	2000	849
14	Iron	mg/l	0.3	1.00	0.15
15	Sulphate (As SO ₄)	mg/l	200	400	-
16	Fluorides (As F)	mg/l	1.0	1.5	0
17	Manganese as Mn	mg/l	0.1	0.3	-
18	Residual Chlorine as Cl ₂	mg/l	0.2	1.0	NIL
19	Arsenic(as aAs)	mg/l	0.01	0.01	-
20	Total Coliform	Per 100 ml.	Nil		0
21	Faecal Coliform	Per 100 ml.			

Tested By –Amrit Lal Rautel

Amrit Lal Rautel
Chemist

PHED Sub Division Beohari
Distt.-Shahdol[M.P.]

-----End of Report-----



Department of Finance , Government of Madhya Pradesh
Acknowledgement Receipt for Online Tax Payment
to M.P. State Government



TIN (Tax payment Identification Number) / Enrollment / Registration No.	-
Depositor/Dealer Name	CENTRAL ACADEMY INTERNATIONAL
Address	705/3 SHANTI KUNJ , MAU, BEOHARI, Shahdol, Madhya Pradesh - 484774
District selected for Payment	Shahdol
Unique Registration Number (URN)	MPTURN200220260010082
Department and Office Name	Public Health Engineering, PHED BEOHARI
Challan Payment Period	2025-2026
Purpose	WATER TASTING

Purpose Details

CRN	Assessment/ Concerning Period	Head of Account	Challan Identification Number (CIN)	Challan No.	Amount(Rs.)
MPT021520022026000021	2026-02-20 to 2030-02-19	0215-02-800-0165 (Other Receipts-Public Health Engineering Services)	ICIC0000055021520022026000463	051/9999999/0215/02/26/000316	1550.00

Total Amount(in figures)	1,550.00
Total Amount(in words)	One Thousand Five Hundred Fifty Rupees Only
Name and Code of the Bank	ICICI BANK (229)
Bank Reference Number	2059780877
Scroll No	000365
Scroll Date	20/02/2026
Date of Transaction / Time of Transaction (HH24:mm:ss)	20/02/2026 20:55:22
Transaction Status	Success